

# WING

## XM244L

### 1. GENERAL WARNING

#### 1.1 PLEASE READ BEFORE USING THIS MANUAL

- This manual is part of the product and should be kept near the instrument for easy and quick reference.
- The instrument shall not be used for purposes different from those described hereunder. It cannot be used as a safety device.
- Check the application limits before proceeding.

#### 1.2 SAFETY PRECAUTIONS

- Check the supply voltage is correct before connecting the instrument.
- Do not expose to water or moisture: use the controller only within the operating limits avoiding sudden temperature changes with high atmospheric humidity to prevent formation of condensation
- Warning: disconnect all electrical connections before any kind of maintenance.
- Fit the probe where it is not accessible by the End User. The instrument must not be opened.
- In case of failure or faulty operation send the instrument back to the distributor or to "Dixell S.p.A." (see address) with a detailed description of the fault.
- Consider the maximum current which can be applied to each relay (see Technical Data).
- Ensure that the wires for probes, loads and the power supply are separated and far enough from each other, without crossing or intertwining.
- In case of applications in industrial environments, the use of mains filters (our mod. FT1) in parallel with inductive loads could be useful.

### 2. GENERAL DESCRIPTION

Model XM244L, 38x185 mm format, is microprocessor based controller suitable for applications on medium or low temperature refrigerating units. It is provided with six relay outputs to control compressor, four defrost – which can be either electrical or hot gas - and the evaporator fans. It is also provided with 5 NTC probe inputs, one for temperature control, the other four to control the defrost end temperature of the evaporators. An output allows the user to programme the parameter list with the "Hot Key".

### 3. CONTROLLING LOADS

#### 3.1 THE COMPRESSOR

The regulation is performed according to the temperature measured by the thermostat probe with a positive differential from the set point: if the temperature increases and reaches set point plus differential the compressor is started and then turned off when the temperature reaches the set point value again.

In case of fault in the thermostat probe the start and stop of the compressor are timed through parameters "CO<sub>n</sub>" and "CO<sub>F</sub>".

#### 3.2 FAST FREEZING

When defrost is not in progress, it can be activated the keypad by holding the ▲ key pressed for about 3 seconds. The compressor operates in continuous mode for the time set through the "CC<sub>t</sub>" parameter. The cycle can be terminated before the end of the set time using the same activation key, ▲ for about 3 seconds.

#### 3.3 DEFROST

Two defrost modes are available through the "tdF" parameter: defrost with electrical heater or hot gas. The defrost interval is control by means of parameter "EdF": (EdF=in) the defrost is made every "ldF" time, (EdF=Sd) the interval "ldF" is calculate through Smart Defrost algorithm (only when the compressor is ON). The controller synchronises the defrost starts and termination. It waits all the evaporators have reached the end defrost temperature before restarting regulation.

#### 3.4 CONTROL OF EVAPORATOR FANS

The fan control mode is selected by means of the "FnC" parameter:  
**FnC=C-n** fans will switch ON and OFF with the compressor and **not run** during defrost;;  
**FnC=O-n** fans will run continuously, but not during defrost

After defrost, there is a timed fan delay allowing for drip time, set by means of the "FnD" parameter.  
**FnC=C-y** fans will switch ON and OFF with the compressor and **run** during defrost;  
**FnC=O-y** fans will run continuously also during defrost

An additional parameter "FS<sub>t</sub>" provides the setting of temperature, detected by the evaporator probe, above which the fans are always OFF. This can be used to make sure circulation of air only if his temperature is lower than set in "FS<sub>t</sub>".

### 4. KEYBOARD



**set** To display and modify target set point; in programming mode it selects a parameter or confirm an operation.  
 By holding it pressed for 3s when max or min temperature is displayed it will be erased.

**↕** To see the max. stored temperature; in programming mode it browses the parameter codes or increases the displayed value. By holding it pressed for 3s the fast freezing cycle is started.

- ↕** To see the min stored temperature; in programming mode it browses the parameter codes or decreases the displayed value.
- ❄** By holding it pressed for 3s the defrost is started.
- ⏻** Switch ON and OFF the instrument.

#### KEY COMBINATIONS

- ↕ + ↕** To lock and unlock the keyboard.
- set + ↕** To enter the programming mode.
- set + ↕** To exit the programming mode.

#### 4.1 USE OF LEDES

Each LED function is described in the following table.

LED	MODE	Function
❄	ON	The compressor is running
❄	FLASHING	- Programming Phase (flashing with LED ❄) - Anti-short cycle delay enabled
🌀	ON	The fan is running
🌀	FLASHING	Programming Phase (flashing with LED 🌀)
❄	ON	The defrost is enabled
❄	FLASHING	Drip time in progress
❄	ON	The Fast Freezing cycle is enabled
🔊	ON	- ALARM signal - In "Pr2" indicates that the parameter is also present in "Pr1"
💡	ON	The light is on

#### 4.2 HOW TO SEE THE MIN TEMPERATURE

- Press and release the ▼ key.
- The "Lo" message will be displayed followed by the minimum temperature recorded.
- By pressing the ▼ key or waiting for 5s the normal display will be restored.

#### 4.3 HOW TO SEE THE MAX TEMPERATURE

- Press and release the ▲ key.
- The "Hi" message will be displayed followed by the maximum temperature recorded.
- By pressing the ▲ key or waiting for 5s the normal display will be restored.

#### 4.4 HOW TO RESET THE MAX AND MIN TEMPERATURE RECORDED

To reset the stored temperature, when max or min temperature is displayed :

- Press SET key until "rST" label starts blinking.

**N.B.** After the installation RESET the temperature stored .

#### 4.5 HOW TO SEE AND MODIFY THE SET POINT

- Push and immediately release the SET key: the display will show the Set point value;
- The SET LED start blinking;
- To change the Set value push the ▲ or ▼ arrows within 10s.
- To memorise the new set point value push the SET key again or wait 10s.

#### 4.6 TO START A MANUAL DEFROST

- Push the DEF key for more than 2 seconds and a manual defrost will start.

#### 4.7 TO ENTER IN PARAMETERS LIST "PR1"

To enter the parameter list "Pr1" (user accessible parameters) operate as follows:

- Enter the Programming mode by pressing the Set and DOWN key for few seconds (🌀 and ❄ start blinking).
- The instrument will show the first parameter present in "Pr1"

#### 4.8 TO ENTER IN PARAMETERS LIST "PR2"

To access parameters in "Pr2":

- Enter the "Pr1" level.
- Select "Pr2" parameter and press the "SET" key.
- The "PAS" flashing message is displayed, shortly followed by "0 -" with a flashing zero.
- Use ▲ or ▼ to input the security code in the flashing digit; confirm the figure by pressing "SET". The security code is "321".
- If the security code is correct the access to "Pr2" is enabled by pressing "SET" on the last digit.

Another possibility is the following: after switching ON the instrument the user can push Set and DOWN keys within 30 seconds.

**NOTE:** each parameter in "Pr2" can be removed or put into "Pr1" (user level) by pressing "SET" + ▼ . When a parameter is present in "Pr1" LED (🔊) is on.

#### 4.9 HOW TO CHANGE THE PARAMETER VALUE

- Enter the Programming mode.
- Select the required parameter with ▲ or ▼ .
- Press the "SET" key to display its value (❄ and 🌀 LED starts blinking).

- Use ▲ or ▼ to change its value.
  - Press "SET" to store the new value and move to the following parameter.
- To exit:** Press SET + UP or wait 15s without pressing a key.  
**NOTE:** the new programming is stored even when the procedure is exited by waiting the time-out.

**4.10 HOW TO LOCK THE KEYBOARD**

- Keep the ▲ and ▼ keys pressed together for more than 3 s the ▲ and ▼ keys.
- The "POF" message will be displayed and the keyboard is locked. At this point it is only possible the viewing of the set point or the MAX o Min temperature stored and to switch ON and OFF the light, the auxiliary output and the instrument.

**TO UNLOCK THE KEYBOARD**

Keep the ▲ and ▼ keys pressed together for more than 3s.

**4.11 ON/OFF FUNCTION**

By pushing the ON/OFF key, the instrument shows "OFF" for 5 sec. and the ON/OFF LED is switched ON.  
 During the OFF status, all the relays are switched OFF and the regulations are stopped;  
**N.B. During the OFF status the Light button is active.**

**4.12 TO SEE THE PROBE VALUES**

- Enter in "Pr2" level.
- Select "Prd" parameter with ▲ or ▼.
- Press the "SET" key to display "Pb1" label alternate with Pb1 value.
- Use ▲ and ▼ keys to display the other probe values.
- Press "SET" to move to the following parameter.

**5. PARAMETER LIST**

**REGULATION**

- Hy Differential:** (0,1÷25,5°C; 1+45°F): Intervention differential for set point, always positive. Compressor Cut IN is Set Point Plus Differential (Hy). Compressor Cut OUT is when the temperature reaches the set point.
- LS Minimum set point limit:** (-50,0°C+SET; -58°F+SET) Sets the minimum acceptable value for the set point.
- US Maximum set point limit:** (SET+110°C; SET+230°F) Set the maximum acceptable value for set point.
- OdS Outputs activation delay at start up:** (0÷255 min) This function is enabled at the initial start up of the instrument and inhibits any output activation for the period of time set in the parameter. (Light can work)
- AC Anti-short cycle delay:** (0÷30 min) interval between the compressor stop and the following restart.
- CCt Thermostat override:** (0min +23h 50min) allows to set the length of the continuous cycle. Can be used, for instance, when the room is filled with new products.
- Con Compressor ON time with faulty probe:** (0÷255 min) time during which the compressor is active in case of faulty thermostat probe. With COn=0 compressor is always OFF.
- COF Compressor OFF time with faulty probe:** (0÷255 min) time during which the compressor is off in case of faulty thermostat probe. With COF=0 compressor is always active.

**DISPLAY**

- CF Temperature measurement unit:** °C = Celsius; °F = Fahrenheit. When the measurement unit is changed the SET point and the values of some parameters have to be modified.
- rES Resolution (for °C):** (in = 1°C; de = 0,1°C) allows decimal point display.  
de = 0,1°C; in = 1 °C
- Lod Local display :** select which probe is displayed by the instrument:  
P1 = Thermostat probe; P2 = Evaporator probe; P3 = not used;

**DEFROST**

- tdF Defrost type:**  
rE = electrical heater (Compressor OFF); in = hot gas (Compressor and defrost relays ON)
- EdF Defrost mode:**  
in = interval mode. The defrost starts when the time "Idf" is expired.
- IdF Interval between defrosts:** (1÷120h) Determines the time interval between the beginning of two defrost cycles.
- dt1 Defrost termination temperature for first evaporator:** (-50,0+110,0°C; -58+230°F) (Enabled only when P2P = yes) sets the temperature measured by the probe 2 which causes the end of defrost on the first evaporator.
- dt2 Defrost termination temperature for second evaporator:** (-50,0+110,0°C; -58+230°F) (Enabled only when P3P = yes) sets the temperature measured by the probe 3 which causes the end of defrost on the second evaporator.
- dt3 Defrost termination temperature for third evaporator:** (-50,0+110,0°C; -58+230°F) (Enabled only when P4P = yes) sets the temperature measured by the probe 4 which causes the end of defrost on the third evaporator.
- dt4 Defrost termination temperature for fourth evaporator:** (-50,0+110,0°C; -58+230°F) (Enabled only when P5P = yes) sets the temperature measured by the probe 5 which causes the end of defrost on the fourth evaporator.
- Md1 (Maximum) duration of defrost for 1st evaporator:** (0÷255 min) When P2P = n, no evaporator probe, it sets the defrost duration for first evaporator, when P2P = y, defrost end is based on temperature, it sets the maximum length of defrost for first evaporator.

- Md2 (Maximum) duration of defrost for 2nd evaporator:** (0÷255 min) When P3P = n, no evaporator probe, it sets the defrost duration for second evaporator, when P3P = y, defrost end is based on temperature, it sets the maximum length of defrost for second evaporator.
- Md3 (Maximum) duration of defrost for 3rd evaporator:** (0÷255 min) When P4P = n, no evaporator probe, it sets the defrost duration for third evaporator, when P4P = y, defrost end is based on temperature, it sets the maximum length of defrost for third evaporator.
- Md4 (Maximum) duration of defrost for 4th evaporator:** (0÷255 min) When P5P = n, no evaporator probe, it sets the defrost duration for first evaporator, when P5P = y, defrost end is based on temperature, it sets the maximum length of defrost for fourth evaporator.
- dFd Display during defrost:**  
rt = real temperature; it = temperature reading at the defrost start; Set = set point; dEF = "dEF" label; dEG = "dEG" label;
- dAd Defrost display time out:** (0÷255 min) Sets the maximum time between the end of defrost and the restarting of the real room temperature display.
- dSd Start defrost delay:**(0÷59min) This is useful when different defrost start times are necessary to avoid overloading the plant.
- Fdt Drain down time:** (0÷60 min.) time interval between reaching defrost termination temperature and the restoring of the control's normal operation. This time allows the evaporator to eliminate water drops that might have formed due to defrost.
- dPO First defrost after start-up:** y = Immediately; n = after the IdF time
- dAF Defrost delay after fast freezing:** (0min÷23h 50min) after a Fast Freezing cycle, the first defrost will be delayed for this time.

**FANS**

- FnC Fan operating mode:**  
C-n = running with the compressor, OFF during the defrost; C-y = running with the compressor, ON during the defrost;  
O-n = continuous mode, OFF during the defrost; O-y = continuous mode, ON during the defrost;
- Fnd Fan delay after defrost:** (0÷255 min) The time interval between the defrost end and evaporator fans start.
- FSt Fan stop temperature:** (-50÷110°C; -58÷230°F) setting of temperature, detected by evaporator probe, above which the fan is always OFF.
- FAP Probe selection for fan nP=** not probe, parameter FST is not considered; P1 = probe 1; P2 = probe 2; P3 = probe 3; P4 = probe 4; P5 = probe 5;

**ALARMS**

- ALC Temperature alarm configuration** rE = High and Low alarms related to Set Point; Ab = High and low alarms related to the absolute temperature.
- ALU High temperature alarm setting:** ALC= rE, 0 + 50°C or 90°F  
ALC= Ab, ALL ÷ 110°C or 230°F when this temperature is reached and after the ALd delay time the HA alarm is enabled.
- ALL Low temperature alarm setting:** ALC = rE, 0 + 50 °C or 90°F  
ALC = Ab, - 50°C or -58°F + ALU when this temperature is reached and after the ALd delay time, the LA alarm is enabled..
- AFH Temperature alarm and fan differential:** (0,1+25,5°C; 1+45°F) Intervention differential for temperature alarm set point and fan regulation set point, always positive.
- ALd Temperature alarm delay:** (0÷255 min) time interval between the detection of an alarm condition and the corresponding alarm signalling.
- dAO Delay of temperature alarm at start-up:** (0min÷23h 50min) time interval between the detection of the temperature alarm condition after the instrument power on and the alarm signalling.
- EdA Alarm delay at the end of defrost:** (0÷255 min) Time interval between the detection of the temperature alarm condition at the end of defrost and the alarm signalling.

**PROBE INPUTS**

- oF1 Thermostat probe calibration:** (-12,0+12,0°C/ -21+21°F) allows to adjust possible offset of the thermostat probe.
- oF2 First Evaporator probe calibration:** (-12,0+12,0°C/ -21+21°F) allows to adjust possible offsets of the first evaporator probe.
- oF3 Second Evaporator probe calibration:** (-12,0+12,0°C/ -21+21°F) allows to adjust possible offsets of the second evaporator probe.
- oF4 Third Evaporator probe calibration:** (-12,0+12,0°C/ -21+21°F) allows to adjust possible offsets of the third evaporator probe.
- oF5 Fourth Evaporator probe calibration:** (-12,0+12,0°C/ -21+21°F) allows to adjust possible offsets of the fourth evaporator probe.
- P2P First Evaporator probe presence:**  
n= not present: the defrost of the first evaporator stops only by time; y= present: the defrost of the first evaporator stops by temperature and time.
- P3P Second Evaporator probe presence:**  
n= not present: the defrost of the second evaporator stops only by time; y= present: the defrost of the second evaporator stops by temperature and time.
- P4P Third Evaporator probe presence:**  
n= not present: the defrost of the third evaporator stops only by time; y= present: the defrost of the third evaporator stops by temperature and time.
- P5P Fourth Evaporator probe presence:**  
n= not present: the defrost of the fourth evaporator stops only by time; y= present: the defrost of the fourth evaporator stops by temperature and time.

**HES** Temperature increase during the Energy Saving cycle : (-30,0°C + 30,0°C / -22+86°F) sets the increasing value of the set point during the Energy Saving cycle.

**TO SET CURRENT TIME AND WEEKLY HOLIDAYS**

- Hur** Current hour (0 + 23 h)
- Min** Current minute (0 + 59min)
- dAY** Current day (Sun + SAte)
- Hd1** First weekly holiday (Sun + nu) Set the first day of the week which follows the holiday times.
- Hd2** Second weekly holiday (Sun + nu) Set the second day of the week which follows the holiday times.
- Hd3** Third weekly holiday (Sun + nu) Set the third day of the week which follows the holiday times.

**N.B.** Hd1,Hd2,Hd3 can be set also as "nu" value (Not Used).

**TO SET ENERGY SAVING TIMES**

- ILE** Energy Saving cycle start during workdays: (0 + 23h 50 min.) During the Energy Saving cycle the set point is increased by the value in HES so that the operation set point is SET + HES.
- dLE** Energy Saving cycle length during workdays: (0 + 24h 00 min.) Sets the duration of the Energy Saving cycle on workdays.
- ISE** Energy Saving cycle start on holidays. (0 + 23h 50 min.)
- dSE** Energy Saving cycle length on holidays (0 + 24h 00 min.)
- HES** Temperature increase during the Energy Saving cycle (-30+30°C / -54+54°F) sets the increasing value of the set point during the Energy Saving cycle.

**TO SET DEFROST TIMES**

- Ld1+Ld8** Workday defrost start (0 + 23h 50 min.) These parameters set the beginning of the eight programmable defrost cycles during workdays. Ex. When Ld2 = 12.4 the second defrost starts at 12.40 during workdays.
- Sd1+Sd8** Holiday defrost start (0 + 23h 50 min.) These parameters set the beginning of the eight programmable defrost cycles on holidays. Ex. When Sd2 = 3.4 the second defrost starts at 3.40 on holidays.

**N.B. :** To disable a defrost cycle set it to "nu"(not used).

**Ex.** If Ld6=nu ; the sixth defrost cycle is disabled


**OTHER**

- Adr** **RS485 serial address** (1+247): Identifies the instrument address when connected to a ModBUS compatible monitoring system.
- dP1** **Thermostat Probe display:** (read only) display the temperature values of the thermostat probe Pb1 .
- dP2** **First evaporator probe display:** (read only) display the temperature values of the first evaporator probe Pb2.
- dP3** **Second evaporator probe display:** (read only) display the temperature values of the second evaporator probe Pb3.
- dP4** **Third evaporator probe display:** (read only) display the temperature values of the third evaporator probe Pb4.
- dP5** **Fourth evaporator probe display:** (read only) display the temperature values of the fourth evaporator probe Pb5.
- rEL** **Release software:** (read only) Software version of the microprocessor.
- Ptb** **Parameter table:** (read only) it shows the original code of the **dixell** parameter map.
- Pr2** **Access to the protected parameter list** (read only).


**6. INSTALLATION AND MOUNTING**

Instruments **XM244L** shall be mounted on vertical panel, in a 150x31 mm hole, and fixed using two screws Ø 3 x 2mm. To obtain an IP65 protection grade use the front panel rubber gasket (mod. RG-L). The temperature range allowed for correct operation is 0 - 60 °C. Avoid places subject to strong vibrations, corrosive gases, excessive dirt or humidity. The same recommendations apply to probes. Let the air circulate by the cooling holes.


**6.1 CUT OUT**



**6.2 MOUNTING WITH KEYBOARD COVER OPENING DOWNWARD**



**6.3 MOUNTING WITH KEYBOARD COVER OPENING UPWARD**



**7. ELECTRICAL CONNECTIONS**

The instruments are provided with screw terminal block to connect cables with a cross section up to 2,5 mm² for the digital and analogue inputs. Relays and power supply have a Faston connection (6,3mm). Heat-resistant cables have to be used. Before connecting cables make sure the power supply complies with the instrument's requirements. Separate the probe cables from the power supply cables, from the outputs and the power connections. Do not exceed the maximum current allowed on each relay, in case of heavier loads use a suitable external relay.  
**N.B.** Maximum current allowed for all the loads is 20A.

**7.1 PROBE CONNECTIONS**

The probes shall be mounted with the bulb upwards to prevent damages due to casual liquid infiltration. It is recommended to place the thermostat probe away from air streams to correctly measure the average room temperature. Place the defrost termination probe among the evaporator fins in the coldest place, where most ice is formed, far from heaters or from the warmest place during defrost, to prevent premature defrost termination.

**8. USE OF THE PROGRAMMING "HOT KEY"**

The Wing units can **UPLOAD** or **DOWNLOAD** the parameter list from its own E2 internal memory to the "Hot Key" and vice-versa.

**8.1 DOWNLOAD (FROM THE "HOT KEY" TO THE INSTRUMENT)**

1. Turn OFF the instrument by means of the ON/OFF key, remove the TTL serial cable if present, insert the "Hot Key" and then turn the Wing ON.
2. Automatically the parameter list of the "Hot Key" is downloaded into the Wing memory, the "DoL" message is blinking. After 10 seconds the instrument will restart working with the new parameters.
3. Turn OFF the instrument remove the "Hot Key", plug in the TTL serial cable, then turn it ON again.

At the end of the data transfer phase the instrument displays the following messages: "end" for right programming. The instrument starts regularly with the new programming. "err" for failed programming. In this case turn the unit off and then on if you want to restart the download again or remove the "Hot key" to abort the operation.

**8.2 UPLOAD (FROM THE INSTRUMENT TO THE "HOT KEY")**

1. Turn OFF the instrument by means of the ON/OFF key and remove the TTL serial cable if present; then turn it ON again.
2. When the Wing unit is ON, insert the "Hot key" and push ▲ key; the "uPL" message appears.
3. Push "SET" key to start the UPLOAD; the "uPL" message is blinking.
4. Turn OFF the instrument remove the "Hot Key", plug in the TTL serial cable, then turn it ON again.

At the end of the data transfer phase the instrument displays the following messages: "end" for right programming. "err" for failed programming. In this case push "SET" key if you want to restart the programming again or remove the not programmed "Hot key".

**9. ALARM SIGNALS**

Message	Cause	Outputs
"P1"	Thermostat probe failure	Alarm output ON; Compressor output according to parameters "CO" and "COF"

"P2"	First Evaporator probe failure	Alarm output ON; Other outputs unchanged
"P3"	Second Evaporator probe failure	Alarm output ON; Other outputs unchanged
"P4"	Third Evaporator probe failure	Alarm output ON; Other outputs unchanged
"P5"	Fourth Evaporator probe failure	Alarm output ON; Other outputs unchanged
"HA"	Maximum temperature alarm	Alarm output ON; Other outputs unchanged
"LA"	Minimum temperature alarm	Alarm output ON; Other outputs unchanged
"EE"	Data or memory failure	Alarm output ON; Other outputs unchanged

The alarm message is displayed until the alarm condition is recovery.  
All the alarm messages are showed alternating with the room temperature except for the "P1" which is flashing. To reset the "EE" alarm and restart the normal functioning press any key, the "rst" message is displayed for about 3s.

9.1 SILENCING BUZZER

Once the alarm signal is detected the buzzer can be silenced by pressing any key.

9.2 "EE" ALARM

The dixell instruments are provided with an internal check for the data integrity. Alarm "EE" flashes when a failure in the memory data occurs. In such cases the alarm output is enabled.

9.3 ALARM RECOVERY


Probe alarms : "P1" (probe1 faulty), "P2" "P3" "P4" "P5"; they automatically stop 10s after the probe restarts normal operation. Check connections before replacing the probe.

Temperature alarms "HA" and "LA" automatically stop as soon as the thermostat temperature returns to normal values or when the defrost starts.

10. TECHNICAL DATA

- Housing: self extinguishing ABS.
- Case: facia 38x185 mm; depth 76mm
- Mounting : panel mounting in a 150x31 mm panel cut-out with two screws.  $\varnothing$  3 x 2mm.  
Distance between the holes 165mm
- Protection: IP20.
- Frontal protection: IP65 with frontal gasket mod RG-L. (optional)
- Connections: Screw terminal block  $\leq$  2,5 mm<sup>2</sup> heat-resistant wiring and 6,3mm Faston
- Power supply: 230Vac or . 110Vac  $\pm$  10%; Power absorption: 7VA max.
- Display: 3 digits, red LED, 14,2 mm high.
- Inputs: 2 NTC or PTC probes
- Digital input: 1 free voltage
- Relay outputs: **Total current on loads MAX. 20A**  
compressor: relay SPST 8(3) A, 250Vac  
defrost 1, 2, 3, 4: relay SPST 8(3) A, 250Vac  
fans: relay SPDT 8(3) A, 250Vac
- Other output : alarm buzzer (optional)
- Data storing : on the non-volatile memory (EEPROM).
- Kind of action: 1B; Pollution grade: normal; Software class: A.
- Operating temperature: 0+60 °C; Storage temperature: -25+60 °C.
- Relative humidity: 20+85% (no condensing)
- Measuring and regulation range: NTC probe: -40+110°C (-58+230°F)
- Resolution: 0,1 °C or 1°C or 1 °F (selectable).
- Accuracy (ambient temp. 25°C):  $\pm$ 0,5 °C  $\pm$ 1 digit

11. CONNECTIONS



12. DEFAULT SETTING VALUES

Label	Name	Range	Default	Level
<b>REGULATION</b>				
Set	Set point	LS+US	-5	---
Hy	Differential	0,1+25,5 °C; 1+45°F	2	Pr1
LS	Minimum set point	-50,0°C+SET; - 58°F+SET	-30	Pr2
US	Maximum set point	SET + 110°C SET + 230°F	20	Pr2
OdS	Outputs activation delay at start up	0+255 min.	0	Pr2
AC	Anti-short cycle delay	0+30 min.	1	Pr2
CCt	Compressor ON time during fast freezing	0 + 23h 50 min.	0	Pr2
CO <sub>n</sub>	Compressor ON time with faulty probe	0+255 min.	15	Pr2
CO <sub>F</sub>	Compressor OFF time with faulty probe	0+255 min.	15	Pr2
<b>DISPLAY</b>				
CF	Temperature measurement unit	°C + °F	°C	Pr2
rES	Resolution (integer/decimal point)	in + de	dE	Pr2
Lod	Local display	P1 + r2	P1	Pr2
<b>DEFROST</b>				
tdF	Defrost type	rE, in	rE	Pr2
EdF	Defrost mode	in, rtc	in	Pr2
ldF	Interval between defrost cycles	1+120h	6	Pr2
dt1	Defrost termination temperature (1°Evaporator)	-50,0+110°C; - 58+230°F	8	Pr2
dt2	Defrost termination temperature (2°Evaporator)	-50,0+110°C; - 58+230°F	8	Pr2

dt3	Defrost termination temperature (3°Evaporator)	-50,0+110°C; - 58+230°F	8	Pr2
dt4	Defrost termination temperature (4°Evaporator)	-50,0+110°C; - 58+230°F	8	Pr2
Md1	(Maximum) length for 1° defrost	0+255 min.	30	Pr2
Md2	(Maximum) length for 2° defrost	0+255 min.	30	Pr2
Md3	(Maximum) length for 3° defrost	0+255 min.	30	Pr2
Md4	(Maximum) length for 4° defrost	0+255 min.	30	Pr2
dFd	Displaying during defrost	rt, it, SET, dEF, dEG	dEF	Pr2
dAd	MAX display delay after defrost	0+255 min.	30	Pr2
dSd	Start defrost delay	0+59min	0	Pr2
Fdt	Draining time	0+60 min.	0	Pr2
dPO	First defrost after start up	n + y	no	Pr2
dAF	Defrost delay after fast freezing	0 + 23h 50 min.	0	Pr2
<b>FANS</b>				
FnC	Fans operating mode	C-n, C-y, O-n, O-y	c-n	Pr2
Fnd	Fans delay after defrost	0+255 min.	10	Pr2
FS <sub>t</sub>	Fans stop temperature	-50,0+110°C; - 58+230°F	2.0	Pr2
FAP	Fan probe selection	nP; P1; P2; P3; P4; P5	P2	Pr2
<b>ALARMS</b>				
ALC	Temperature alarms configuration	rE+Ab	Ab	Pr2
ALU	MAXIMUM temperature alarm	-50,0+110°C; - 58+230°F	110	Pr1
ALL	minimum temperature alarm	-50,0+110°C; - 58+230°F	-40	Pr1
AFH	Temperature alarm and fan differential	0,1+25,5 °C; 1+45°F	2	Pr2
AL <sub>d</sub>	Temperature alarm delay	0+255 min.	15	Pr2
dAO	Delay of temperature alarm at start up	0 + 23h 50 min.	1,3	Pr2
EdA	Alarm delay at the end of defrost	0+255 min.	20	Pr2
<b>ANALOGUE INPUTS</b>				
oF1	Thermostat probe calibration	-12,0+12,0°C; - 21+21°F	0	Pr1
oF2	First Evaporator probe calibration	-12,0+12,0°C; - 21+21°F	0	Pr2
oF3	Second Evaporator probe calibration	-12,0+12,0°C; - 21+21°F	0	Pr2
oF4	Third Evaporator probe calibration	-12,0+12,0°C; - 21+21°F	0	Pr2
oF5	Fourth Evaporator probe calibration	-12,0+12,0°C; - 21+21°F	0	Pr2
P2P	First Evaporator probe presence	n + y	y	Pr2
P3P	Second Evaporator probe presence	n + y	y	Pr2
P4P	Third Evaporator probe presence	n + y	y	Pr2
P5P	Fourth Evaporator probe presence	n + y	y	Pr2
HES	Temperature increase during the Energy Saving cycle	-30+30°C / - 22+86°F	0	Pr2
<b>TIME AND WEEKLY HOLIDAYS</b>				
Hur	Current hour	0 + 23	0	Pr2
Min	Current minute	0 + 59	0	Pr2
dAY	Current day	Sun + SAT	Sun	Pr2
Hd1	First weekly holiday	Sun + SAT - nu	nu	Pr2
Hd2	Second weekly holiday	Sun + SAT - nu	nu	Pr2
Hd3	Third weekly holiday	Sun + SAT - nu	nu	Pr2
<b>ENERGY SAVING TIMES</b>				
ILE	Energy Saving cycle start during workdays	0 + 23h 50 min.	0	Pr2
dLE	Energy Saving cycle length during workdays	0 + 24h 00 min.	0	Pr2
ISE	Energy Saving cycle start on holidays	0 + 23h 50 min.	0	Pr2
dSE	Energy Saving cycle length on holidays	0 + 24h 00 min.	0	Pr2
HES	Temperature increase during the Energy Saving cycle	-30+30°C / - 54+54°F	0	Pr2
<b>DEFROST TIMES</b>				
Ld1	1 <sup>st</sup> workdays defrost start	0 + 23h 50 min. - nu	6.0	Pr2
Ld2	2 <sup>nd</sup> workdays defrost start	0 + 23h 50 min. - nu	13.0	Pr2
Ld3	3 <sup>rd</sup> workdays defrost start	0 + 23h 50 min. - nu	21.0	Pr2
Ld4	4 <sup>th</sup> workdays defrost start	0 + 23h 50 min. - nu	nu	Pr2
Ld5	5 <sup>th</sup> workdays defrost start	0 + 23h 50 min. - nu	nu	Pr2
Ld6	6 <sup>th</sup> workdays defrost start	0 + 23h 50 min. - nu	nu	Pr2
Ld7	7 <sup>th</sup> workdays defrost start	0 + 23h 50 min. - nu	nu	Pr2
Ld8	8 <sup>th</sup> workdays defrost start	0 + 23h 50 min. - nu	nu	Pr2
Sd1	1 <sup>st</sup> holiday defrost start	0 + 23h 50 min. - nu	6.0	Pr2
Sd2	2 <sup>nd</sup> holiday defrost start	0 + 23h 50 min. - nu	13.0	Pr2
Sd3	3 <sup>rd</sup> holiday defrost start	0 + 23h 50 min. - nu	21.0	Pr2
Sd4	4 <sup>th</sup> holiday defrost start	0 + 23h 50 min. - nu	nu	Pr2

<b>Sd5</b>	5 <sup>th</sup> holiday defrost start	0 ÷ 23h 50 min. - nu	nu	Pr2
<b>Sd6</b>	6 <sup>th</sup> holiday defrost start	0 ÷ 23h 50 min. - nu	nu	Pr2
<b>Sd7</b>	7 <sup>th</sup> holiday defrost start	0 ÷ 23h 50 min. - nu	nu	Pr2
<b>Sd8</b>	8 <sup>th</sup> holiday defrost start	0 ÷ 23h 50 min. - nu	nu	Pr2
	<b>OTHER</b>			
<b>Adr</b>	Serial address	0÷247	1	Pr2
<b>dP1</b>	Thermostat Probes display	---	---	Pr1
<b>dP2</b>	First evaporator Probes display	---	---	Pr1
<b>dP3</b>	Second evaporator Probes display	---	---	Pr1
<b>dP4</b>	Third evaporator Probes display	---	---	Pr1
<b>dP5</b>	Fourth evaporator Probes display	---	---	Pr1
<b>rEL</b>	Software release	---	1.0	Pr2
<b>Ptb</b>	Map code	---	---	Pr2
<b>Pr2</b>	Access parameter list	---		Pr1

**dixell** s.p.A

Z.I. Via dell'Industria, 27 - 32010 Pieve d'Alpago (BL) ITALY  
tel. +39 - 0437 - 98 33 - fax +39 - 0437 - 98 93 13  
<http://www.dixell.com> E-mail: [dixell@dixell.com](mailto:dixell@dixell.com)